


**Mbsm.pro, Compressor,  
Toshiba, PH160X2-4LU, 12000  
btu, 220 v, 1ph, rla 6.5 a,  
fla 40 a, 35  $\mu$ F**

written by Lilianne | 19 February 2022



**PH160X2-4LU**

THERMALLY  
PROTECTED  
R22

PH1 H250 V220.240 LRA35  
LOW MPa TP 2.0 AP1.4 DP1.3  
HIGH MPa TP 4.4 AP2.9 DP2.8



50302558

TOSHIBA CORPORATION  
MADE IN JAPAN

**WARNING/DANGER**

FAILURE TO FOLLOW THESE INSTRUCTIONS  
COULD RESULT IN SERIOUS PERSONAL INJURY


1 FOLLOW RECOGNIZED SAFETY PRACTICES AND  
WEAR PROTECTIVE GOGGLES

2 DO NOT OPERATE COMPRESSOR OR PROVIDE  
ANY ELECTRIC POWER TO THIS UNIT UNLESS  
THIS COVER IS IN PLACE AND SECURED

3 DO NOT REMOVE THIS COVER UNTIL ALL  
ELECTRICAL SOURCES HAVE BEEN  
DISCONNECTED

4 IF REFRIGERANT LEAK IS SUSPECTED AROUND  
TERMINALS RELIEVE ALL PRESSURE FROM  
SYSTEM BEFORE TOUCHING OR DISTURBING  
ANYTHING INSIDE THIS TERMINAL BOX

5 MATCHING OF COMPRESSOR TERMINAL  
SERIALS TO THE TERMINAL BOX  
IS NECESSARY FOR PROPER  
OPERATION



Private Picture Copyright: [WWW.MBSM.PRO](http://WWW.MBSM.PRO)

Mbsm.pro, Compressor, Toshiba, PH160X2-4LU, 12000 btu, 220 v,  
1ph, rla 6.5 a, fla 40 a, 35 µF